



Wisconsin Department of Agriculture, Trade and Consumer Protection
 Bureau of Weights and Measures
 P.O. Box 7837, Madison, WI 53707-7837
 (608) 224-4942

FOR OFFICE USE ONLY

Wis. Admin. Code §ATCP 93.100


UST CORROSION PROTECTION TEST/SURVEY REPORT

Personal information you provide may be used for purposes other than that for which it was originally collected (s. 15.04(1)(m) Wis. Stats.).

OWNER INFORMATION			
CUSTOMER NAME:	COMPANY NAME:	TELEPHONE: () -	E-MAIL:
STREET ADDRESS:		<input type="checkbox"/> CITY <input type="checkbox"/> VILLAGE <input type="checkbox"/> TOWN	STATE ZIP
SITE INFORMATION			
FACILITY NAME:	FACILITY ID#:	ASSIGNED ANNIVERSARY MONTH	DATE OF TESTING/SERVICING
STREET ADDRESS:		<input type="checkbox"/> CITY <input type="checkbox"/> VILLAGE <input type="checkbox"/> TOWN	STATE ZIP
TESTER INFORMATION			
SUBMITTING PARTY:		CONTACT PERSON	WORK ORDER #:
TELEPHONE: () -	CELL PHONE: () -	E-MAIL:	
TESTER NAME:		SURVEY TYPE:	
Wisconsin Certification Type:		<input type="checkbox"/> Routine	<input type="checkbox"/> Re-Survey
Wisconsin Certification #:		<input type="checkbox"/> Post-Repair or Modification	<input type="checkbox"/> Post-Installation
CP CRITERION APPLIED:		TYPE OF SYSTEM: <input type="checkbox"/> Impressed Current <input type="checkbox"/> Galvanic	
<input type="checkbox"/> -0.850 volts "ON" (Galvanic)	<input type="checkbox"/> 100 mV Polarization (Impressed)	<input type="checkbox"/> -0.850 volts "INSTANT-OFF" (Impressed)	
SECTION I: Tester's evaluation (mark only one)			
<input type="checkbox"/> PASS	All protected structures at this site pass the cathodic protection survey and it is judged that adequate cathodic protection has been provided to the UST system. Complete Section III.		
<input type="checkbox"/> FAIL	One or more protected structures at this site fail the cathodic protection survey and it is judged that adequate cathodic protection has not been provided to the UST system. Complete Section III.		
<input type="checkbox"/> INCONCLUSIVE	If the remote and the local do not both indicate the same test result on all protected structures (both pass or both fail), inconclusive is indicated and the survey must be evaluated and/or conducted by a corrosion expert. Go to Section II.		
CP TESTER (Print):		CP TESTER'S SIGNATURE:	
SECTION II: Corrosion expert's evaluation (mark only one)			
The survey must be conducted and/or evaluated by a corrosion expert when: a) supplemental anodes or other changes in the cathodic protection system are made; b) stray current may be affecting buried metallic structures or c) an inconclusive result was indicated.			
<input type="checkbox"/> PASS	All protected structures at this site pass the cathodic protection survey and it is judged that adequate cathodic protection has been provided to the UST system. Complete Section III.		
<input type="checkbox"/> FAIL	One or more protected structures at this site fail the cathodic protection survey and it is judged that adequate cathodic protection has not been provided to the UST system. Complete Section III.		
COMMENT:			
CORROSION EXPERT'S NAME (Print):		CORROSION EXPERT'S NAME	
COMPANY NAME:		WISCONSIN CORROSION EXPERT CERTIFICATION #:	REVIEW DATE:
STREET ADDRESS:		CITY	STATE ZIP
SECTION III: Action required as a result of this evaluation (mark only one)			
<input type="checkbox"/> NONE	Cathodic protection is adequate. Test again within regulatory window or by:		(DATE):
<input type="checkbox"/> REPAIR & RETEST Send report to: DATCPStorageTanks@wisconsin.gov	Cathodic protection is not adequate. (Corrosion Expert evaluation in Section II is required if adding supplemental anodes, impressed current, or if stray current is suspected.) Repair/modification is necessary by:		(DATE):
<input type="checkbox"/> TESTING INDICATES INCONCLUSIVE Send report to: DATCPStorageTanks@wisconsin.gov	Wisconsin Corrosion Expert evaluation required within 30 days:		(DATE):

Provide a drawing or use the space below:

NOTE: Requirements for periodic corrosion testing of tank systems (tank and/or piping) can be found in Wis. Admin. Code § ATCP 93.520(1)(c)



Include Service Station Diagram that shows all Tanks and Dispensers in relation to Buildings and Streets. Include on the drawing the location of the Submersible Pumps, Fills, ATGs, Risers, and Vents. If this is an Impressed Current System, show Rectifier location. Clearly indicate on diagram where all Test Readings were taken by identifying each structure being tested (UST by Product Stored or Product Piping by Tank/Dispenser) and numbering each individual test location. Show on drawing if corrosion test leads and/or test stations exist for the USTs or product piping and their location. Show locations of all reference electrodes. Indicate **North** on the drawing.